



CUBICLE TRACKING SPECIFICATIONS – 6000 SERIES

DIVISION 10190

Part 1 – General

1.1 Summary

- A. Work included in this Section: Provision of cubicle curtains and tracks.
- B. Related Work Not Included in this Section: Backing for cubicle curtain tracks.

1.2 System Description

- A. Performance Requirements
 - 1. Provide cubicle curtains that conform to the following requirements of regulatory agencies and the quality control of Fabtex, Inc.
- B. Fire Performance Characteristics
 - 1. Provide curtains that conform to NFPA 701 (Fire Tests for Flame and Resistant Textiles and Films) and California Title 19 regulations.

1.3 Submittals

- A. Product Data
 - 1. Manufacturer's printed product data for each type of cubicle curtain specified.
- B. Fabric Samples
 - 1. Swatch cards of fabric (memo) samples illustrating fabric color and weave.
- C. Track Samples
 - 1. Verification samples of cubicle track, 6 inch (153mm) long, in full size with carriers and end stops.

1.4 Delivery, Storage and Handling

- A. Deliver and store packaged products in original containers with seals unbroken and labels intact until time of use.
- B. Inspect materials at delivery to assure that specified products have been received.
- C. Store delivered products inside in a clean, safe and dry environment.

1.5 Warranty

- A. Standard Fabtex Limited Warranty against material and manufacturing defects for a period of 1 year from the date of the installation.

Part 2 – Products

2.1 Fabtex, Inc. 6000 Series Cubicle Track

- A. Description: Ceiling mounted cordless aluminum track with matching splices; carriers with hooks; cordless hand traverse operations.
- B. Acceptable manufacturer
 - 1. Fabtex Inc., (800) 778-2791 in accordance with specifications, drawings, and contract documents.
- C. Substitutions: Not Permitted
- D. Provide all cubicle tracks from a single source.
- E. Track Material
 - 1. Cubicle Tracking System: Fabtex 6000 Series heavy duty extruded clear anodized aluminum cubicle track systems.
 - 2. Track to be delivered in straight lengths up to 20 feet (6.1m).
 - 3. Configuration Sections: Provide illustrations of bends.
 - a. Standard Bends
 - i. 90 degree bend with a 12 inch (305mm) radius
 - ii. 45 degree bend with a 12 inch (305mm) radius
 - iii. 180 degree bend with a 60 inch (1524mm) radius
 - iv. 90 degree bend with a 60 inch (1524mm) radius
 - b. Custom Bends
 - i. Provide drawing with dimensions. Template may be required
 - 4. Suspension Tubing System (optional)



CUBICLE TRACKING SPECIFICATIONS – 6000 SERIES

DIVISION 10190

Part 2 – Products (continued)

- a. ¼" Square Aluminum Tubing color: Clear Anodized
 - b. Length of Suspension tubing should be 18" minimum
 - c. A complete suspension tube assembly should be anchored every 24"
 - i. 6000-ST Suspension Tubing – cut to drop length
 - ii. 6000-06 Ceiling Bracket – attaches tube to ceiling
 - iii. 6000-08 Track Bracket – attaches tube to track
 - d. Where track ends meet a wall, 6000-07 Track End Wall Brackets are required for proper anchoring
- 2.1 Cubicle Curtains
- A. Description: 100% polyester cubicle curtains. Fabric is to be opaque, washed, flame retardant and closely woven.
 - B. Acceptable Manufacturer:
 1. Fabtex Inc., (800) 778-2791 in accordance with specifications, drawings, and contract documents.
 - C. Substitutions: Not Permitted
 - D. Provide all cubicle curtains from a single source.
 - E. Construction:
 1. Height of curtains to be from 18 inches (457mm) below ceiling mounted track to a distance of not more than 10-12 inches (254-308mm) from the floor.
 - F. Curtains to have 110 percent fullness, width to be determined by length of track to ensure proper enclosure.
 - G. Form top and bottom hems by a triple fold securely sewn with edges and panels seams 1 inch (25mm) overlapped lock stitched.
 - H. Provide flat washed nickel-plated ½ inch (12.7mm) brass eyelets inserted in the top hem at 6 inches (152mm) on center.
 - I. Sew a Fabtex identification label and cleaning instructions on the top hem of each curtain to identify the width of the curtain.
 - J. Fabricate curtains with a 20 inch (508mm) mesh cloth with ½ inch (12.7mm) holes. Mesh is to be flame retardant, washable, and dry cleanable.
 - K. Fabric railroading
 1. Vertical striped patterns are to be railroaded. All other patterns will be pattern matched and sewn with vertical seams.
 - L. Plaids
 1. Cut plaid pattern materials utilizing a straight edge; thread pulling to mark cutting line is not an acceptable method.
 - M. Fabric
 1. Select solid or patterned fabric from manufacturer's selection.
 - N. Mesh (optional)
 1. Mesh is not required when utilizing the 6000-ST suspension tubing system
 2. Mesh Selection
 - a. 100% nylon mesh with ½" diameter holes.
 - b. Mesh is to be opaque, washable, flame retardant and woven.
 - c. Integrated Header and Selvage
 - d. Minimum of 3.3 ounces per square yard
 3. Acceptable Manufacturer:
 - a. Fabtex Inc., (800) 778-2791 in accordance with specifications, drawings, and contract documents.
 4. Substitutions: Not Permitted
 5. Provide all cubicle curtain mesh from a single source.
 6. Construction



CUBICLE TRACKING SPECIFICATIONS – 6000 SERIES

DIVISION 10190

Part 2 – Products (continued)

- a. Size: 20" (51cm)
- b. Top Integral Header: 1.75" (45mm)
- c. Bottom Integral Selvage: 0.5" (13mm)
7. Color (select one)
 - a. Snow White, Earth, or Tusk
8. Attachment (mesh to fabric)
 - a. Standard
 - i. Over lock attachment folded over and ¼" double needed stitched.
 - b. Snap Attach
 - i. Mesh designed as one piece with nickel plated brass snaps located along the bottom edge, spaced top match snaps on fabric panel(s)
 - ii. Fabric
 - Made as one piece with snaps along top edge spaced every 6" (152mm) on center.
 - Made in 68" overlapping panels with snaps along top edge and double snaps on each leading panel edge.
 - c. Hook and Loop Attach
 - i. Hook tape sewn long bottom edge of mesh and Loop tape sewn along top edge of fabric
- O. Attachment Method (curtain to track)
 1. Nickel-plated brass grommets, size #0, spaced every 6" (152mm) on center.
 - a. Color: Silver
 2. Hook and Loop tape sewn along the top edge of the mesh.

Part 3 – Execution

3.1 Preparation

- A. Coordinate details with other work supporting, adjoining, or otherwise contacting items as required to ensure proper installation.
- B. Verify that surfaces and above ceiling supports/backing are installed by the general contractor and are ready to receive work.

3.2 Examination

- A. Examine construction to support, adjoin, or otherwise contact and verify that:
 1. Dimensions are correct.
 2. Backing is available and installed where required.
 3. Exposed finishes have been applied, and setting conditions are dry, clean, and otherwise proper for installation.
- B. Do not install items until unsatisfactory conditions have been corrected.

3.3 Installation

- A. Install track in accordance with approved Fabtex, Inc. recommendations and reviewed Shop Drawings.
- B. Typical Fastenings: Use machine screws or bolts to metal backing.
- C. Drill and tap mounting surfaces for mounting hardware as required.
- D. Install track in one piece when less than 14 feet (6.1m) long and with no more than one splice for each additional 14 feet (6.1m).
- E. Form corner bends with 12 inch (308mm) radius.
- F. Butt Joints
 1. Secure with splices.
- G. Carriers

CUBICLE TRACKING SPECIFICATIONS – 5000 SERIES



DIVISION 10190

Part 3 – Execution (continued)

1. Furnish one carrier per every 4 inches (102mm) of track plus 10 percent extra for each track length.
 - H. End Stops
 1. Provide at both ends with removable pull-out at one end of each track length.
 - I. Furnish tag designating proper size curtain at curtain stacking end of runs.
- 3.4 Cleaning
- A. At completion of installation, remove any debris and clean surfaces in accordance with the Fabtex, Inc. clean-up and maintenance instructions.